

CERTIFICATE of Conformity



Certificate No.: MK 69241668 0001

Test Report No.: 28203795 002

Certificate Holder: VENTILATION SYSTEMS PrJSC
1, Mikhaïla Kotzubinskïego str.
UA-01030 Kiev
Ukraine

Manufacturer: VENTILATION SYSTEMS PrJSC
1, Mikhaïla Kotzubinskïego str.
UA-01030 Kiev
Ukraine

Product: Duct fan

Identification:

Type designation:	Rated power input:
VKOMx 150	36W
VKOMx 200	43W
VKOMx 250	68W
VKOMx 315	110W

Rated voltage: 230V, 50Hz
Degree of protection: IPX4
Protection class: I
where x = blank or z
(blank: enclosure-steel with polymeric coating)
(z : enclosure-galvanized steel)

Tested according to: EN 60335-1:2002+A1+A11+A2+A12+A13+A14
EN 60335-2-80:2003+A1+A2
EN 62233:2008

This certificate refers to the above mentioned product. This is to certify that the test sample is in conformity with the requirements stated above. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Date of Issue:

Budapest, 2012.01.25



TÜV Rheinland InterCert Kft. – Product Certification Body — H-1132 Budapest, Váci út 48/A-B — www.tuv.hu
IT_07-D-Pe_4_0